

certificate  
no. **BAU 24031**  
dated 2024-02-21

Translation In any case, the German original shall prevail.

## EuroTest Certificate

Name and address of the holder of the certificate: (customer) **SBH Tiefbautechnik GmbH  
Ferdinand-Porsche-Str. 8  
52525 Heinsberg  
GERMANY**

Product designation: **Pile chamber shoring system**

Type: **400 series**

Testing based on: **EN 13331-2:2002  
EN 13331-1:2002  
DIN 4124:2012**

Test report: **2018 0176 003, 2023 0135 03**

Further details: **Panel thickness 120 mm up to panel length 4.22 m,  
permissible bending moment M=111.1 kNm  
Panel thickness 170 mm up to panel length 7.02 m,  
Permissible bending moment M=279.1 kNm**

**Intended use:**

**In accordance with the manufacturer's instructions for use and operation.**

**Maximum permissible earth pressure:**

**See manufacturer's instructions for use and operation.**

**Subsequent certificate to number BAU 19031.**


**The manufacturer is also Certificate holder.**

The type tested complies with the test basis specified above.

The holder of the certificate is entitled to affix the ET-mark shown overleaf to the products complying with the type tested.

The present certificate including the right to affix the ET-mark is valid until: **2029-02-11**

Further provisions concerning the validity, the extension of the validity and other conditions are laid down in the Rules of Procedure for Testing and Certification.

  
Dipl.-Ing. (FH) Franz Welsch  
Deputy Head of Certification Body

